



- NOTES:
- 1.) CONCRETE PAD SHALL BE 8" THICK AND SHALL CONTAIN A LAYER OF REBAR.
  - 2.) CONCRETE MIXTURE SHALL BE A 2500 POUND MIX.
  - 3.) 1" CONDUIT TO BE USED FOR UTILITY COMPANY GROUND ROD.
  - 4.) 4" CONDUIT TO BE USED FOR UTILITY COMPANY PRIMARY CONDUIT.
  - 5.) CONTRACTOR SHALL BE RESPONSIBLE FOR SIZING SECONDARY CONDUIT.
  - 6.) CENTER OF SECONDARY CONDUIT(S) TO BE LOCATED AS NOTED.
  - 7.) CONTRACTOR SHALL NOTIFY UTILITY COMPANY PRIOR TO POURING PAD IN ORDER TO VERIFY CONDUIT STUB OUT LOCATIONS.



**THREE - PHASE  
PADMOUNT TRANSFORMER  
STANDARD PAD**

**DATE:** 05-2020

**UGT-CPD**