



NOTES:

1. All clearances to be in conformance to the most stringent requirements of the NESC, NEC or other codes of the governmental or regulating authorities as applicable.
2. If length of conduit exceeds 10 feet, coupling is permitted on end adjacent to the meter.
3. Bolivar Energy Authority Engineering Staff must spot meterbase location.

BEA

BOLIVAR ENERGY AUTHORITY

THROUGH ROOF
MAST TYPE SERVICE
ASSEMBLY GUIDE

DATE: 8-2008

K4.2G
(M24-10)